



# CERTIFICATE

No.: 22155501

<b>Name and Address of the Manufacturer</b>	CREANOVA DOO BEOGRAD, Kamenjareva, 22300 Stara Pazova, Republic of Serbia
<b>Product description</b>	HVAC system AHU01
<b>Test report number</b>	ZK-063-22-I / 14.07.2022
<b>Test Standard</b>	EN ISO 14644-3:2022
<b>Accepted Air Class</b>	GMP D according to EU GMP
<b>Name of tests applied</b>	Airflow of the tests Installed filter system leakage test Air pressure test and visualization Temperature test Classification of air cleanliness by particle concentration

The product defined above has been tested according to EN ISO 14644-3:2020 by LAB Prova D.O.O which is accredited according to EN ISO/IEC 17025 by ATS. According to test results, The HVAC system AHU01 met the test requirements as successfully.

It should be looked at in the test report for more information. This certificate is related to the samples defined in the test report. The responsibility for the test result belongs to the laboratory.



The validity of the certificate can be verified by our website.

Valid Until : 01/08/2025

Date of Issue : 02/08/2022



Inspecco

INSPECCO Zertifizierungs - und Inspektionsdienste GmbH

Brauereistr. 13 D-68723  
Planksadt / Germany  
Phone: +49 06202 9548657

